

# **Oceanside Union Free School District**

## **Water Testing Background**



*As of 3/17/2017*

As you may know, there have been reports of lead being found in water from fountains and sinks in schools across the country, including on Long Island. Our goal in Oceanside is to safeguard the health and well-being of our students and staff by ensuring that the drinking water in our buildings is safe. Therefore, the Oceanside School District voluntarily began water quality testing in all of our schools in May by utilizing JC Broderick, an independent environmental consultant.

All initial (Phase 1) sampling of high priority water outlets which are outlets used for cooking or drinking was performed, analyzed and reported to the District in September. The Phase 1 report containing results is posted to the website without building floor plans for security purposes. These reports are available to be reviewed in their entirety by making an appointment with the Oceanside UFSD Buildings & Grounds Department at 516-594-2333. **All Phase 1 tests & results are now 100% compliant.**

New legislation has now transferred jurisdiction of this matter from the Environmental Protection Agency (EPA) to the Department of Health (DOH) due to new regulations. More information can be found at: [http://www.health.ny.gov/environmental/lead/child\\_care\\_providers.htm](http://www.health.ny.gov/environmental/lead/child_care_providers.htm). The updated regulation not only required the sampling of high priority water outlets, but also required the sampling of all low and non-listed priority water outlets located on the school property. These are outlets that are not normally used for cooking or drinking, such as bathroom sinks, custodial slop sinks, science lab sinks, etc. **Testing of these sources is labeled as “Phase 2 Samplings”.**

The school district initialized “Phase 2 Sampling” at all school buildings. As of this communication, six schools have been remediated and re-tests were performed. Please see the attached internal reports on remediation efforts district-wide.

**School #2****Phase 2 Remediation Efforts**

<b>Room #</b>	<b>Map Location</b>	<b>Remidation type</b>	<b>Retest 2/11/17</b>
20		27 Filter Ordered	Pass
2		49 Sign / Faucet Replacement	Pass
1		50 Sign / Faucet Replacement	Pass
4		58 Sign / Faucet Replacement	Filter Ordered
5		59 Sign / Faucet Replacement	pass
Bath room 110		67 Sign / Faucet Replacement	pass
111		68 Sign / Faucet Replacement	Pass
11		75 Sign / Faucet Replacement	Pass
12		76 Sign / Faucet Replacement	Pass
Handicapp bath rm 6		96 Sign / Faucet Replacement	Pass
16		80 Sign / Faucet Replacement	Pass
19		83 Sign / Faucet Replacement	Filter Ordered
20		84 Sign / Faucet Replacement	Pass
22		86 Sign / Faucet Replacement	Pass
24		88 Sign / Faucet Replacement	Pass
25		25 Sign / Faucet Replacement	Pass
28		93 Sign / Faucet Replacement	Pass
Exterior Hose Bibs	101-102-103-104-106	Shut Off	

**School #3****Phase 2 Remediation Efforts**

<b>Room #</b>	<b>Map Location</b>	<b>Remediation type</b>	<b>Retest 2/11/17</b>
Gym Storage Room		38 Shut Off	Filter Ordered
A5		45 Sign / Faucet Replacement	Pass
A6		22 Sign / Faucet Replacement	Pass
A3		21 Sign / Faucet Replacement	Pass
Hand wash		52 Sign / Faucet Replacement	Pass
Kitchen		53 Shut Off	Pending
Kitchen Hand wash		24 Sign / Faucet Replacement	Filter Ordered
a10		66 Sign / Faucet Replacement	Filter Ordered
a11		67 Sign / Faucet Replacement	Pass
a7		68 Sign / Faucet Replacement	Pass
a9		77 Sign / Faucet Replacement	Pass
art		78 Sign / Faucet Replacement	Filter Ordered
art		79 Filter Ordered	Filter Ordered
art		81 Sign / Faucet Replacement	Filter Ordered
art		82 Sign / Faucet Replacement	Filter Ordered
art		83 Sign / Faucet Replacement	Filter Ordered
Exterior Hose Bibs		89 Shut Off	

**School #4****Phase 2 Remediation Efforts**

<b>Room #</b>	<b>Map Location</b>	<b>Remidation type</b>	<b>Retest 2/11/17</b>
210		16 Shut Off/ Faucet Replacement	Pass
Slop Sink by Fac Rm		22 Sign / Faucet Replacement	Restricted
205		23 Shut Off/ Faucet Replacement	Filter Ordered
204		24 Shut Off/ Faucet Replacement	Filter Ordered
Princ		26 Sign / Faucet Replacement	Filter Ordered
Kitchen		28 Sign / Faucet Replacement	Pass
Kitchen		28a Sign / Faucet Replacement	Pass
Kitchen		28C Sign / Faucet Replacement	Filter Ordered
Art Rm		38a Shut Off/ Faucet Replacement	Pass
Art Rm		39c Shut Off/ Faucet Replacement	Filter Ordered
Slop Sink boiler rm		42 Sign / Faucet Replacement	Restricted
211		57 Shut Off/ Faucet Replacement	Filter Ordered

**School #5**

**Phase 2 Remediation Efforts**

<b>Room #</b>	<b>Map Location</b>	<b>Remidation type</b>	<b>Retest 2/11/17</b>
Band Room		37 Sign /Faucet Replacement	Filter Ordered
Gym Kitchen		51 Sign /Faucet Replacement	Filter Ordered
2nd fl Girls bath		56 Sign /Faucet Replacement	Pass
2nd fl Girls bath		58 Sign /Faucet Replacement	Pass
2nd fl Girls bath		59 Sign /Faucet Replacement	Pass

**School #6**  
**Phase 2 Remediation Efforts**

<b>Room #</b>	<b>Map Location</b>	<b>Remidation type</b>	<b>Retest 2/11/17</b>
Slop Sink 312		72 Sign /Faucet Replacement	Restricted
Slop Sink 316		78 Sign /Faucet Replacement	Restricted
Slop Sink 319		82 Sign /Faucet Replacement	Restricted
218		87 Shut off /Faucet Replacement	Filter Ordered
216		100 Shut off /Faucet Replacement	Pass
214		103 Shut off /Faucet Replacement	Pass
214		104 Shut off /Faucet Replacement	Pass
Girls bath by 223		103 Shut off /Faucet Replacement	Pass
Slop Sink by 201		118 Sign /Faucet Replacement	Restricted
Bath faucet rm 203		123 Shut off /Faucet Replacement	Pass
Slop Sink GYM Vest		126 Sign /Faucet Replacement	Restricted
Slop Sink Indoor playground		128 Shut off /Faucet Replacement	Restricted
Service conn Boiler room		196 Sign /Faucet Replacement	Restricted
Bath Indoor play ground		205 Shut off /Faucet Replacement	Filter Ordered
Bath room faucet gym closet bath		218 Shut off /Faucet Replacement	Pass
Bath faucet gym storage		220 Shut off /Faucet Replacement	Pass
Superintendents office		224 Sign /Faucet Replacement	Pass
Exterior Hose Bibs	183-186-187-195-	Shut off	Restricted

**School #7****Phase 2 Remediation Efforts**

<b>Room #</b>	<b>Map Location</b>	<b>Remediation type</b>	<b>Retest Date</b>
Sci Lab Test taps all N-216	33 - 64	Sign	
Sci Storage room N219		65 Sign	
Sci Faucet Rm N219		68 Sign	
Sci Faucet Rm N219		69 Sign	
Sci Lab Test taps all N-219	71-97	Sign	
Sci Faucet N200		100 Sign	
Sci Faucet N222		101 Sign	
Girls rm by N222		104 Shut Off / Faucet Replacement	
Girls Rm By N222		107 Shut Off / Faucet Replacement	
Boys bath by N233		111 Shut Off / Faucet Replacement	
Boys bath by N233		114 Shut Off / Faucet Replacement	
Sci Faucet N227		115 Sign	
Sci Faucet N230		117 Sign	
Sci Faucet N230		118 Sign	
Sci Faucet N230		120 Sign	
Sci Faucet N230		121 Sign	
Sci Lab Taps N233	122-142	Sign	
Womans bathroom by S219		162,164 Sign / Faucet Replacement	
Science faucet s213		166,167 Sign	
Sci Faucet in Storage rm S213		168,169 Sign	
Sci Faucet in S212		173,170 Sign	
Sci Storage S224		175 Sign	
Sci Faucet S224		176 Sign	
SS by Rm s224		177 Sign / Faucet Replacement	
Bath S232		178 Sign / Faucet Replacement	
Sci Faucet S229		179,180 Sign / Faucet Replacement	
Girls bath by N118		189,192 Sign / Faucet Replacement	
N118		200 Sign / Faucet Replacement	
boys rm by kitchen		209 Sign / Faucet Replacement	
Womans bath By Kitchen		212 Sign / Faucet Replacement	
Faucet in Boys bath by Kitche		215 Sign / Faucet Replacement	
Kitchen		227,228 Sign / Faucet Replacement	
Spray Nozzle		233 Sign / Faucet Replacement	
Bathroom Faucet Girls Locker		242 Sign / Faucet Replacement	
Bathroom Faucet Girls Locker		244 Sign / Faucet Replacement	
Faucet in Mens rm by S131		260 Sign / Faucet Replacement	
Bathroom faucet in Boys lock		263 Sign / Faucet Replacement	
Faucet in 127b		271 Sign / Faucet Replacement	
S124		278,279,280 Sign / Faucet Replacement	
S123		281,283 Sign / Faucet Replacement	
S122		284,285,287 Sign / Faucet Replacement	
Field House womans bath		303,304 Sign / Faucet Replacement	
Faucet in the field house kitcl		305 Sign / Faucet Replacement	
Hose Bibs Exterior	297,298,300,296,275	Shut off	

**School #8**

**Phase 2 Remediation Efforts**

<b>Room #</b>	<b>Map Location</b>	<b>Remidation type</b>	<b>Retest Date 1/28/17</b>
2a		45 Sign / Faucet Replacement	Pass
17		61 Shut Off /Faucet Replacement	Filter ordered
25		66 Shut Off /Faucet Replacement	Pass
27		67 Shut Off /Faucet Replacement	Pass
30		69 Shut Off /Faucet Replacement	Pass
26		73 Shut Off /Faucet Replacement	Pass
Svc Conn Boileroom		90 Sign / Faucet Replacement	Pass
Kitchen Sprayer		2 Sign / Faucet Replacement	Pass
Exterior Hose Bib	101,104	Shut Off	Restricted



**School #9E & #9M****Phase 2 Remediation Efforts**

<b>Room #</b>	<b>Map Location</b>	<b>Remidation type</b>	<b>Retest Date</b>
109		80 Sign / Faucet Replacement	
207		95 Sign / Faucet Replacement	
207		96 Sign / Faucet Replacement	
207		97 Sign / Faucet Replacement	
203		101 Sign / Faucet Replacement	
a307		117 Sign / Faucet Replacement	
a303		120 Sign / Faucet Replacement	
A301		121,122 Sign / Faucet Replacement	
224	125-126-128-130-131	Sign / Faucet Replacement	
Slop Sink Custodial New Addition		151 Sign / Faucet Replacement	
C122		176 Sign / Faucet Replacement	
Bathroom of C122		177 Sign / Faucet Replacement	
C211		189 Sign / Faucet Replacement	