

# Oceanside Union Free School District

## Water Testing Progress Report



*As of 7/11/2016*

As you may know, there have been reports of lead being found in water from fountains and sinks in schools across the country, including on Long Island. Our goal in Oceanside is to safeguard the health and well-being of our students and staff by ensuring that the drinking water in our buildings is safe. Therefore, the Oceanside School District voluntarily began water quality testing in all of our schools in May.

The chart below is provided to communicate the most current information as it relates to the Oceanside UFSD.

<b>Building</b>	<b>Status</b>
School 2	Testing complete; one source with minimally elevated levels of lead was removed and will be replaced. Re-testing of replacement unit to be scheduled.
School 3	Testing complete; eight sources with minimally elevated levels of lead were removed and replaced. Re-testing of replacement units is complete; awaiting lab results.
School 4	Testing complete; no elevated levels of lead found.
School 5	Testing complete; no elevated levels of lead found.
School 6 & Castleton HS	Testing complete; three sources with minimally elevated levels of lead were removed and will be replaced. Re-testing of replacement units to be scheduled.
School 7: Oceanside HS	Testing complete; one source with minimally elevated levels of lead was removed and will be replaced. Re-testing of replacement unit to be scheduled.
School 8	Testing complete; eight sources with minimally elevated levels of lead were removed and replaced. Re-testing of replacement units is complete; awaiting lab results.

OMS/9E	Testing complete; six sources (3 @ OMS & 3 @ 9E) with minimally elevated levels of lead were removed and will be replaced. Re-testing of replacement units to be scheduled.
--------	---

The District's plan is in conformance with the Environmental Protection Agency's **"3T"** *Program for reducing lead in drinking water in schools: Training, Testing & Telling*.

Full document is available at:

[https://www.epa.gov/sites/production/files/2015-09/documents/toolkit\\_leadschools\\_guide\\_3ts\\_leadschools.pdf](https://www.epa.gov/sites/production/files/2015-09/documents/toolkit_leadschools_guide_3ts_leadschools.pdf)